



# Annual Drinking Water Quality Report



## East Valley Estates MT0004514

Annual Water Quality Report for the period of January 1 to December 31, 2023

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report please contact Tina Malkuch at 406 253 5301.

Public Participation Opportunities: The East Valley Estates HOA routinely meets once a year. Look for your notice within your water billing statements or individually mailed to you annually announcing the time and place.

### Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
  - Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
  - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
  - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
  - Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Source Water Information for East Valley Estates

which is classified as a *Ground Water* system

The source water assessment report for your water system provides additional information on your source water's susceptibility to contamination. To access this report please go to: <https://deq.mt.gov/water/Programs/dw-sourcewater>

On the webpage look under "4. Make Results of the Delineation and Assessment Available to the Public" and then click on the grey box called "Review Source Water Assessment Reports".

East Valley Estates utilizes the listed water sources below:

| Water Source Name         | Water Source Type |
|---------------------------|-------------------|
| WELL 2 (WEST) GWIC 223738 | Well              |
| WELL 1 (EAST) GWIC 223739 | Well              |

East Valley Estates subdivision has a total of 28 lots in Phase II and 17 lots in Phase I. Of these 45 lots, 16 lots have been built on in phase I and 27 lots are built on in phase II. Your subdivision has two wells and one pressure control house that has 12 captive air tanks (Pressure Tanks).

Well #1 (GWIC 223739) is the northeasterly well in the Park Area. Well #1 is 280 feet deep, pumps about 140 to 150 gpm with a 7.5 hp submersible pump. The casing is 8" steel casing, is perforated between 266 and 280 feet below the top of the casing. The static water level is at about 4 feet below the top of the casing.

Well #2 (GWIC 223738) is located in the Park Area also. Well #2 is 280 feet deep and pumps about 140 to 150 gpm with a 7.5 hp submersible pump. The casing is 8" steel and perforated between 268 to 280 feet below the top of the casing. The static water level is 3 feet below the top of the casing. Both wells are grouted from 0 to 25 feet with water rights for 95 gpm or 48.60 acre feet. There is about 2000 linear feet of 4" PVC mains, one air release valve and two blow offs in Phase I, one at Holt Stage and one in Fairview Court. The air release is located between lots 2 and 3 on the property line in the Right of Way. There are 4 main line valves that are exercised yearly.

## Water Quality Test Results Definitions

**Definitions:** The following tables contain scientific terms and measures, some of which may require explanation.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Avg:** Regulatory compliance with some MCLs is based on running an annual average of monthly samples.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level or MCL:** The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum residual disinfectant level or MRDL:** The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**N/A:** Not applicable.

**ND:** Not detectable at testing limit.

**Nephelometric Turbidity Unit (NTU)** – Measure of the clarity or cloudiness of water. Turbidity more than 5 NTU is just noticeable to the typical person.

**Picocuries per liter (pCi/L)** – Measure of the radioactivity in water.

**ppb:** micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

**ppm:** milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

**Secondary Maximum Contaminant Level (SMCL):** SMCLs are established as guidelines to assist public water systems in managing their drinking water for aesthetic considerations, such as taste, color, and odor. These contaminants are not considered to present a risk to human health at the SMCL.

**Treatment Technique or TT:** A required process intended to reduce the level of a contaminant in drinking water.

The State of Montana DEQ requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

| Lead and Copper |              |      |                   |                 |                 |       |           |   |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|---|
| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination  |
| Copper          | 2023         | 1.3  | 1.3               | 0.05            | 0               | ppm   | N         | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |

## Regulated Contaminants

| Contaminant Group: Inorganic Contaminants   |                 |                        |                 |      |     |       |           |  |
|---|-----------------|------------------------|-----------------|------|-----|-------|-----------|--|
| Regulated Contaminants                      | Collection Year | Highest Level Detected | Range of Levels | MCLG | MCL | Units | Violation | Likely Source of Contamination   |
| Barium                                      | 2022            | 0.36                   | .36 - .36       | 2    | 2   | ppm   | N         | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.                                |
| Chromium                                    | 2022            | 2                      | 2 - 2           | 100  | 100 | ppb   | N         | Discharge from steel and pulp mills; Erosion of natural deposits.  |
| Fluoride                                    | 2022            | 0.04                   | .04 - .04       | 4    | 4   | ppm   | N         | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate<br>[measured as Nitrogen]           | 2023            | 0.04                   | .04 - .04       | 10   | 10  | ppm   | N         | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.                               |
| Contaminant Group: Radioactive Contaminants |                 |                        |                 |      |     |       |           |  |
| Regulated Contaminants                      | Collection Year | Highest Level Detected | Range of Levels | MCLG | MCL | Units | Violation | Likely Source of Contamination   |
| Uranium                                     | 2021            | 0.3                    | .3 - .3         | 0    | 30  | ppb   | N         | Erosion of natural deposits.   |

***Your water system meets or exceeds all established state and federal standards.***

Tina Malkuch  
 Safewater Testing Simplified, Inc.  
 1500 Airport Road  
 Kalispell, MT 59901  
 Phone: 406-253-5301  
 E-Mail: sts2535301@gmail.com  
 Website: www.stsmontana.com