



Annual Drinking Water Quality Report



Two Mile Tract Hoa MT0003328

Annual Water Quality Report for the period of January 1 to December 31, 2023

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report please contact Tina Malkuch at 406 253 5301.

Public Participation Opportunities: We want you to be informed and involved with your water system. To learn more, please attend your annual meeting which is announced by letter once each week for three weeks before the meeting. Annual meetings are usually held the second week in June, in the evening at a neighborhood bar-b-que.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 - Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
 - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
 - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
 - Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information for Two Mile Tract Hoa

which is classified as a *Ground Water* system

The source water assessment report for your water system provides additional information on your source water's susceptibility to contamination. To access this report please go to: <https://deq.mt.gov/water/Programs/dw-sourcewater> On the webpage look under "4. Make Results of the Delineation and Assessment Available to the Public" and then click on the grey box called "Review Source Water Assessment Reports".

Two Mile Tract Hoa utilizes the listed water sources below:

| Water Source Name | Water Source Type |
|-------------------|-------------------|
| WELL 1 GWIC 82783 | Well |

Your water source is a 180 foot drilled well located on the corner of Two Mile Drive and Best View. The well (Well #1 1979) was test pumped for 8 hours producing in excess of 300 gallons per minute. The distribution system has 1550 lineal feet of 6" polyvinyl chloride pipe (PVC) and 1550 lineal feet of 4" polyvinyl chloride pipe. There are 11 pressure tanks that provide storage for the system. Two Mile Tracts HOA has two water rights: one is for 95 gallons per minute with a total annual volume for 33 acre feet (11 million gallons) and the other is for 85 gallons per minute with total annual volume of 15 acre feet (5 million gallons). You have 38 service connections serving 37 homes

Water Quality Test Results Definitions

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Avg: Regulatory compliance with some MCLs is based on running an annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A: Not applicable.

ND: Not detectable at testing limit.

Nephelometric Turbidity Unit (NTU) – Measure of the clarity or cloudiness of water. Turbidity more than 5 NTU is just noticeable to the typical person.

Picocuries per liter (pCi/L) – Measure of the radioactivity in water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Secondary Maximum Contaminant Level (SMCL): SMCLs are established as guidelines to assist public water systems in managing their drinking water for aesthetic considerations, such as taste, color, and odor. These contaminants are not considered to present a risk to human health at the SMCL.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

The State of Montana DEQ requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one-year-old.

| Lead and Copper | | | | | | | | |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|---|
| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination |
| Copper | 2023 | 1.3 | 1.3 | 0.11 | 0 | ppm | N | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |
| Lead | 2023 | 0 | 15 | 2 | 0 | ppb | N | Corrosion of household plumbing systems; Erosion of natural deposits. |

Regulated Contaminants

Contaminant Group: Inorganic Contaminants

| Regulated Contaminants | Collection Year | Highest Level Detected | Range of Levels | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------------|-----------------|------------------------|-----------------|------|-----|-------|-----------|--|
| Barium | 2022 | 0.15 | .15 - .15 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Fluoride | 2022 | 0.1 | .1 - .1 | 4 | 4 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen] | 2023 | 3 | 2.98 - 2.98 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |

Contaminant Group: Radioactive Contaminants

| Regulated Contaminants | Collection Year | Highest Level Detected | Range of Levels | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|-------------------------|-----------------|------------------------|-----------------|------|-----|-------|-----------|--------------------------------|
| Combined Radium 226/228 | 2021 | 1.3 | 1.3 - 1.3 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |
| Uranium | 2021 | 4.6 | 4.6 - 4.6 | 0 | 30 | ppb | N | Erosion of natural deposits. |

Secondary Contaminants

| Secondary Contaminant | Collection Year | Highest Level Detected | Range of Levels | SMCL | Units | Likely Source of Contamination and or Reason for Monitoring |
|-----------------------|-----------------|------------------------|-----------------|------|-------|---|
| MANGANESE | 2023 | 5 | 0 - 5 | 50 | ppb | Natural sources as well as discharges from industrial uses |

Water may naturally have manganese and, when concentrations are greater than 50 ppb, the water may be discolored and taste bad. Over a lifetime, the EPA recommends that people drink water with manganese levels less than 300 ppb and over the short term, EPA recommends that people limit their consumption of water with levels over 1000 ppb, primarily due to concerns about possible neurological effects. Children younger than one year old should not be given water with manganese concentrations over 300 ppb, nor should formula for infants be made with that water for more than a total of 10 days throughout the year.

Your water system meets or exceeds all established state and federal standards.

Tina Malkuch
Safewater Testing Simplified, Inc.
1500 Airport Road
Kalispell, MT 59901
Cell Phone: 406-253-5301
E-Mail: sts2535301@gmail.com
www.stsmontana.com